
RE: 26 Johnson Rd

Manter, Bryan <bmanter@winchester.us>
To: "flharley@flharchitects.com" <flharley@flharchitects.com>

Fri, Jun 24, 2022 at 8:00 AM

Hi Lee –

Based on the information provided the proposed increase of impervious surface is less than 500 sf. Therefore stormwater runoff management is not required.

If the plans change during design where the increase of impervious surface becomes more than 500 sf, then the Applicant will be required to meet Winchester Stormwater Rules and Regulations.

Bryan Manter, P.E.

Assistant Town Engineer

Engineering Department

71 Mount Vernon Street

Winchester, MA 01890

Tel: 781-721-7120

Email: bmanter@winchester.us
